



Applied Energy Symposium and Forum, Renewable Energy Integration with Mini/Microgrids,
REM 2018, 29–30 September 2018, Rhodes, Greece

Importance of considering energy system design during the urban planning process

A.T.D. Perera¹, Silvia Coccolo¹, Sameh Monna², Jean-Louis Scartezzini¹, Dasaraden
Mauree¹

¹ *Solar Energy and Building Physics Laboratory (LESO-PB), Ecole Polytechnique Fédérale de Lausanne (EPFL), CH-1015 Lausanne, Switzerland*

² *Faculty of Engineering and Information Technology, An-Najah National University (Palestine)*

**Corresponding author: dasun.perera@epfl.ch*

Abstract

Maintaining energy efficiency and sustainability at urban scale has become essential for the energy transition. Linking the urban planning and urban energy system design play a vital role in this context. This study evaluates the impact of the urban planning decisions (regarding building stock) on the energy system design and operation. Three scenarios (represent urban planning scenarios) are considered or energy system design for an archetype neighbourhood in Nablus in Palestine. The distinguish difference is these three scenarios have three different albedo values for the building stock (albedo values 0.1, 0.58 and 0.8 named as Scenario A, B and C). A computational platform that combines building simulation, urban climate and energy system optimization (considering Net Present Value (NPV) and Grid Integration Level) is used to assess the three scenarios. The results of the study show that higher albedo values help to reduce the cooling demand. When comparing Scenario A and C annual electricity demand and peak demand has reduced by 8.5% and 20% respectively. However, most of the Pareto solutions of Scenario A outperform Scenario C beside the fact that having higher peak and annual electricity demands. This can be explained using the demand profiles and the solar energy potential. The electricity demand of Scenario A closely follows the solar energy potential which helps to reduce NPV. The study reveals that the annual or peak energy demand is not sufficient enough to compare two scenarios, it is important to consider energy demand pattern and the renewable energy potential where energy system design tool is important. Therefore, it can be concluded that the energy system design tools will play a major role in sustainable urban planning processes.

Copyright © 2018 Elsevier Ltd. All rights reserved.

Selection and peer-review under responsibility of the scientific committee of the Applied Energy Symposium and Forum, Renewable Energy Integration with Mini/Microgrids, REM 2018.

Keywords: Energy hubs; Urban planning; Albedo; Urban Climate

1. Introduction

Rapid depletion of fossil fuel resources, climate change and escalating urban population makes it essential to improve the energy efficiency and sustainability of urban energy infrastructure. However, this is a challenging task which requires the support of multiple parties with different expertise [1]. When considering the demand side, people are often interested on the energy efficiency at building scale. The thermal impact of buildings on the neighbouring buildings and the urban microclimate are often neglected resulting in decreased opportunities to improve the energy efficiency of the urban configuration [2]. Furthermore, improvements in energy demand and generation are conducted separately without much coordination. This makes it important to develop a holistic framework to design energy infrastructure considering different aspect in order to improve the efficiency and sustainability of urban energy infrastructure [3].

Towards achieving this goal, it is important to develop a holistic urban energy model combining building simulation, urban climate simulation and energy system optimization [4]. Such a holistic approach can help to quantify the importance of each factor and subsequently optimize the energy efficiency and sustainability. This study tries to demonstrate the importance of such a holistic approach on urban context specifically focused on evaluating the impact of albedo values of the buildings stock on the energy infrastructure. The impact of the albedo values of external surfaces has been considered in number of studies for a single building from the perspective of energy demand. For example, the impact of albedo values on the peak and annual energy demands has been studied in Ref. [5–9]. Integrating materials with higher external reflectivity has been recommended as a method to mitigate the adverse effects due to the urban heat islanding effect [5]. However, the influences of the albedo values on urban climate, energy demand and more importantly the energy system have not been studied. Building energy demand and urban climate are closely coupled together due to the notable impact of the building stock into the urban climate [10]. Subsequently, energy demand of building stock is linked with energy system designing process. Hence, it is important to consider the close relationship between energy demand, urban climate and energy system sizing. Towards achieving this objective this study uses a holistic platform combining building simulation, urban climate and energy system optimization. The research paper is arranged in the following manner; Section 2 of this paper presents the methodology used in this study. A brief overview about the building simulation model, urban simulation model and energy system optimization is presented in this section. Section 3 presents the results of the study and the discussion.

2. Methodology

A computational platform is developed in this study to consider the influence building energy demand, urban climate and the energy system design. When considering these three, building energy demand and urban climate conditions are closely coupled with each other. Surface temperature of the building stock influences both energy demand of the building and, temperature and wind speed in the urban canopy layer. Magnitude and the fluctuations in the energy demand influence the energy system design process. This makes it important to have a holistic platform considering urban climate, building simulation and energy system optimization.

Considering urban climate and energy demand in urban building stock is a challenging task due to the strong coupling between them. Currently, the combination of macro-scale meteorological models with building simulation models fails to present the drag force effect and turbulence generated [10]. Furthermore, most of the building simulation models neglect the influence of shadowing and boundary layer influence. Hence, these models fail to present as urban heat islanding and cooling pool effect [2,11]. Failure to present such phenomena's will lead to a significant performance gap in the energy system operation [4]. Although computational fluid dynamic (CFD) models are a better way to improve the accuracy, such models take much longer computational time especially when simulating results and it is thus computationally challenging to conduct yearly time series simulations. The Canopy Interface Model (CIM) [12] becomes an attractive solution in such instances to reduce the computational burden while accounting for local scale urban phenomena's. Hence, this study combines CIM with CitySIM [13] a building energy model. CitySim can model the energy demand of a building stock (representing each building through a

single zone) while considering the radiation heat transfer among the buildings. The influence of the urban climate is introduced to the CityCim model through a coupling with CIM.

2.1 Coupling between CitySim and CIM models

CIM is a 1D urban canopy model which can be used in an offline mode. It resolved the flow in the vertical direction and computes values for the wind speed in the x and y direction as well as the air temperature. For each calculation, the column module can be forced with values for the top most column and with the surface temperature for the ground and for the obstacles present. The obstacles are represented as occupied surfaces and volumes and their dimensions can be specified for each level of the module, giving an improved representation of the surface in the mixing length and drag force calculation.

CIM has been coupled with CitySim to improve the boundary conditions in both models [11]. In the first iteration, CitySim is ran with the standard meteorological data (such as Meteonorm[14]) to obtain the surface temperatures. The surface temperatures obtained as well as the wind speed and air temperatures are then used as boundary conditions for CIM. The output from CIM including the “urban effect” is then used as input for CitySim to calculate the energy demand.

2.2 Simulation case study

The case study is conducted for Nablus, a city in Palestine. The city of Nablus (32°13' N, 35°16' E) is situated in the northern part of the West Bank and it presents a Csa climate (C: temperate; s: dry summer; a: hot summer). The city is located at 550 m above the sea level and it presents a particular topography, as it is positioned in a narrow valley, between the Mount Ebal and Mount Gerizim. In this paper, the study focuses on the Al-Habaleh district, within the old city, characterized by dense constructions and narrow streets. The physical and geometrical data required for setting up the model were previously defined [15]. The meteorological data are provided by the tool Meteonorm [14], representing a Typical Meteorological Year (TMY). In order to understand and to quantify the impact of the radiative environment on the CIM model, as well as on the energy demand (for heating and cooling) of buildings, the global albedo of the site was varied from 0.1 to 0.8. Figure 1 shows the 3D model of the city, as designed according to the proposed methodology, where the geometrical properties of the city are redesigned as function its density.




Fig. 1 3D model of the city of Nablus. Current city design and proposed geometrical model

2.3 Computational model for energy system optimization

Multi-energy hub catering electricity, heating and cooling demand of the location are considered in this study [16–

18]. The energy hub consists of renewable energy technologies such as solar PV (SPV) and wind turbines. An internal combustion generator (ICG) and a battery bank are considered as dispatchable source and storage. A heat-pumps and air-conditioners are used to cater the heating and cooling demand of the building stock respectively which converts the heating and cooling load to an electricity demand. The energy hub interacts with the medium voltage grid when catering the demand of the energy hub. Curtailments are introduced for both selling and purchasing electricity to and from the grid in order to maintain the stability of the grid. Computational model is developed to model the energy and cash flow of the system. The computational model assisted by hourly simulation to map the decision space variables into the objective space. Hourly wind speed, solar irradiation, energy demands for cooling, heating and electricity are taken for the simulation of the energy system considering a time period of one year. Power generation from the wind turbines (P_t^{Wind}) and SPV panels are computed using Eq. (1-2) for time

step t .

$$P_t^{SPV} = G_t^\beta \eta_t^{SPV} A^{SPV} x^{SPV} \zeta, \quad \forall t \in T \quad (1)$$

$$P_t^{Wind} = \tilde{P}_t^W (v_t) x^w \eta^{Losses}, \quad \forall t \in T \quad (2)$$

In Eq. 1, G_t^β , η_t^{SPV} , A^{SPV} , x^{SPV} and ζ denote the global solar irradiation on the tilted PV panel, the efficiency of the SPV panel, the number of PV panels obtained using the optimization algorithm. In Eq. 2, x^w and η^{Losses} denote the number of wind turbines in the system (which is obtained using the optimization algorithm) and the power losses. The Durisch model [19] is used to consider the SPV panel efficiency considering the global solar irradiation on the tilted SPV panel, cell temperature, and air-mass is used to compute the efficiency of the SPV panels.

Grid integration level (GI) and net present value (NPV) of the system are considered as the objective functions for the optimization problem. Grid integration level presents the autonomy level of the energy system and often used as an objective function in the multi-objective optimization of energy system along with the cost [16]. Grid integration level is formulated according to Eq. 3.

$$GI = \sum_{\forall t \in T} P_t^{IG} / \sum_{\forall t \in T} E_t^D, \quad \forall t \in T \quad (3)$$

In this equation, P_t^{IG} and P_t^D present the energy imported from the grid and the demand of the energy hub. The net present value (NPV) of the system is modeled in a similar way after considering initial investment and present value of all the operation and maintenance costs. A bi-level dispatch strategy based on fuzzy automata theory is used to consider the operation of the internal combustion generator, energy interactions with the battery bank and the grid. A detailed description about the dispatch strategy can be found in Ref. [16]. A Pareto multi objective optimization is conducted using evolutionary algorithms.

3.0 Results and discussion

The energy demand of the archetype building stock is computed considering three albedo values. Subsequently, the demand profile for heating and cooling is assessed in Section 3.1 and the impact of the demand profile is assessed in Section 3.2.

3.1 Demand profile for the three scenarios

The hourly heating and cooling demand profiles are presented in Fig. 2. When analyzing the heating and cooling demand profiles it is clear that higher albedo ratio will result in significant reduction in cooling demand as reported in literature [5–9]. However, it will also increase the heating demand especially during the winter period. The influence of albedo value on the cooling demand is visible when analyzing both peak and annual cooling demands (Table 1). A significant reduction in both peak and annual cooling demands has taken place due to the changes in the building external surface. The peak cooling demand has reduced from 870 kWhs to 247 kWhs while annual

cooling demand has reduced from 886 MWh to 72 MWh when moving from Scenario A to C. However, the influence of albedo values on the peak and annual electricity demand behaves in a different manner since it considers catering both heating and cooling demands using heat pumps and air-conditioners. A notable reduction in both peak and annual electricity demand can be observed when moving from Scenario A to C. However, the lowest peak and annual demand can be observed in Scenario B. This can be explained by considering the heating demand. Although higher albedo values can help to minimize the cooling demand it will increase the heating demand during the winter since it minimizes the solar heat gain during the winter. A moderate albedo will balance both heating and cooling requirements such as scenario B reducing both annual and peak electricity demands (such as Scenario B).




Fig. 2: Hourly variation of electricity demand after converting heating and cooling demands into electricity

Table 1: Peak and annual electricity and cooling demands for the three scenarios

	Annual electricity demand (considering heat-pumps and air conditioners) (MWh)	Peak electricity demand (kWh)	Annual cooling demand (MWh)	Peak cooling demand (kWh)
Scenario A (Albedo 0.1)	713	315	886	870
Scenario B (Albedo 0.58)	636	237	324	540
Scenario C (Albedo 0.8)	652	250	72	247

3.2 Pareto fronts for the three scenarios

Pareto fronts obtained using multi-objective optimization for the three scenarios are presented in Fig. 3(a). When analyzing the three Pareto fronts it is observed that Scenario B represents the lowest cost although it is not the one having the highest albedo ratio. However, the comparison of the Pareto fronts for Scenario A and C brings quite an interesting observation. Pareto solutions of Scenario C, outperforms Scenario A for a part in the Pareto front when the grid integration levels are low (as marked in Box E). However, the conditions totally change when increasing the grid interaction levels further. Pareto solutions of Scenario A outperform Scenario C with a notable cost margin especially in the sections within Box F. Scenario A is having a peak and annual electricity demand respectively 20% and 8.5% higher than Scenario C. Even after catering such a high energy demand the Pareto solutions for Scenario A can maintain a lower cost compared to Scenario C except for the part marked in Box E. To understand the situation further, installed SPV capacities are plotted for the three scenarios (Fig. 3 (b)). Figure 3b clearly shows that installed PV capacity for Scenario A is notably high when compared to Scenario C (highlighted in Box G). As a

result, there will be higher PV generation during the summer period which will be relatively cheaper (due to the abundant solar energy potential). The excess SPV generation will compensate the higher cooling demand due to lower albedo value. Therefore, the net present value of design solution for Scenario A becomes cheaper when compared to Scenario C. When considering Scenario A and C it can be concluded that minimum demand scenario might not be the optimum for the energy system; especially when considering the seasonal variation of the renewable energy potential. Hence, it is important to consider the urban planning scenarios along with energy system designs besides being limited to minimizing the energy demand. This will make it important to have holistic design platforms that consider building simulation, urban climate and energy system design.




Fig. 3 (a) Pareto fronts for the three scenarios and (b) installed SPV capacity for the Pareto solutions

Conclusions

The study reveals that changing albedo values of the building stock can help to reduce the cooling demand. When considering the annual energy demand having a moderate albedo value will be helpful when considering both heating and cooling energy demands. When comparing the Pareto fronts obtained for Scenarios A and C it is revealed that reduction in annual or peak demand itself will not guarantee a cost reduction for the energy system. It is important to consider the demand pattern as well as potential for renewable energy sources. This makes it important to have energy designing tool embedded into the urban planning process.

References

- [1] Guen ML, Mosca L, Perera ATD, Cocco S, Mohajeri N, Scartezzini J-L. Improving the energy sustainability of a Swiss village through building renovation and renewable energy integration. *Energy Build* 2018;158:906–23. doi:10.1016/j.enbuild.2017.10.057.
- [2] Moonen P, Defraeye T, Dorer V, Blocken B, Carmeliet J. Urban Physics: Effect of the micro-climate on comfort, health and energy demand. *Front Archit Res* 2012;1:197–228. doi:10.1016/j.foar.2012.05.002.
- [3] Mauree D, Cocco S, Perera A, Nik V, Scartezzini J-L, Naboni E, et al. A New Framework to Evaluate Urban Design Using Urban Microclimatic Modeling in Future Climatic Conditions. *Sustainability* 2018;10:1134. doi:10.3390/su10041134.
- [4] Perera ATD, Cocco S, Scartezzini J-L, Mauree D. Quantifying the impact of urban climate by extending the boundaries of urban energy system modeling. *Appl Energy* 2018;222:847–60. doi:10.1016/j.apenergy.2018.04.004.
- [5] Simpson JR, McPherson EG. The effects of roof albedo modification on cooling loads of scale model residences in Tucson, Arizona. *Energy Build* 1997;25:127–37. doi:10.1016/S0378-7788(96)01002-X.
- [6] Morini E, Touchaei A, Castellani B, Rossi F, Cotana F, Morini E, et al. The Impact of Albedo Increase to Mitigate the Urban Heat Island in Terni (Italy) Using the WRF Model. *Sustainability* 2016;8:999. doi:10.3390/su8100999.
- [7] Mansouri O, Belarbi R, Bourbia F. Albedo effect of external surfaces on the energy loads and thermal comfort in buildings. *Energy Procedia* 2017;139:571–7. doi:10.1016/j.egypro.2017.11.255.
- [8] Muñoz AZR and CB. Albedo Effect and Energy Efficiency of Cities. *Sustain Dev - Energy Eng Technol - Manuf Environ* 2012. doi:10.5772/29536.
- [9] Yaghoobian N, Kleissl J. Effect of reflective pavements on building energy use. *Urban Clim* 2012;2:25–42.

- doi:10.1016/j.uclim.2012.09.002.
- [10] Frayssinet L, Merlier L, Kuznik F, Hubert J-L, Milliez M, Roux J-J. Modeling the heating and cooling energy demand of urban buildings at city scale. *Renew Sustain Energy Rev* 2018;81:2318–27. doi:10.1016/j.rser.2017.06.040.
 - [11] Mauree D, Coccolo S, Kaempf J, Scartezzini J-L. Multi-scale modelling to evaluate building energy consumption at the neighbourhood scale. *PLOS ONE* 2017;12:e0183437. doi:10.1371/journal.pone.0183437.
 - [12] Mauree D, Blond N, Kohler M, Clappier A. On the Coherence in the Boundary Layer: Development of a Canopy Interface Model. *Front Earth Sci* 2017;4. doi:10.3389/feart.2016.00109.
 - [13] Robinson D. *Computer Modelling for Sustainable Urban Design: Physical Principles, Methods and Applications*. Routledge; 2012.
 - [14] Remund J, Müller S, Kunz S. *Meteonorm*. Global meteorological database. Version 7 2015.
 - [15] Coccolo S, Monna S, Kämpf J, Scartezzini J-L. Energy demand and urban microclimate of old and new residential districts in a hot arid climate. *PLEA*, 2016.
 - [16] Perera ATD, Nik VM, Mauree D, Scartezzini J-L. Electrical hubs: An effective way to integrate non-dispatchable renewable energy sources with minimum impact to the grid. *Appl Energy* 2017;190:232–48. doi:10.1016/j.apenergy.2016.12.127.
 - [17] Perera ATD, Nik VM, Mauree D, Scartezzini J-L. An integrated approach to design site specific distributed electrical hubs combining optimization, multi-criterion assessment and decision making. *Energy* 2017;134:103–20. doi:10.1016/j.energy.2017.06.002.
 - [18] Kuehner AL, Mdeihli N, Coccolo S, Perera ATD, Mohajeri N, Scartezzini J-L. Extending building integrated photovoltaics (BiPV) using distributed energy hubs. A case study in Cartigny, Switzerland. *Energy Procedia* 2017;122:487–92. doi:10.1016/j.egypro.2017.07.299.
 - [19] Durisch W, Bitnar B, Mayor J-C, Kiess H, Lam K, Close J. Efficiency model for photovoltaic modules and demonstration of its application to energy yield estimation. *Sol Energy Mater Sol Cells* 2007;91:79–84. doi:10.1016/j.solmat.2006.05.011.